

## DECLARATION OF CONFORMITY

### 1. Declaration of Conformity

This Declaration of Conformity is made against the Electromagnetic Compatibility Directive (89/336/EEC).

### 2. Product model

Field Logger

### 3. Product description

The Field Logger is a data acquisition and recording instrument with 8 universal inputs that can operate either as a RTU linked to a PC for on line recording and supervision or as a stand alone data logger with real time clock and internal data memory.

### 4. Conformity

The Field Logger conforms to the following standards:

- EMC: EN 61326-1:1997 and EN 61326-1/A1:1998

<u>Emission:</u>	<u>Standard</u>	<u>Description</u>	
	CISPR11/EN55011	Conducted and Irradiated emission	

  

<u>Immunity:</u>	<u>Standard</u>	<u>Description</u>	<u>Severity level</u>
	EN61000-4-2	Electrostatic Discharge test	CD 4 kV AD 8 kV
	EN61000-4-3	Radiated Susceptibility test	10 V/m
	EN61000-4-4	Electrical Fast Transients	±2 kV (on power supply) ±1 kV (on other inputs)
	EN61000-4-5	Voltage surge	±2 kV
	EN61000-4-6	Conducted disturbances, Induced by radio frequency fields	3 V,RMS
	EN61000-4-8	Magnetic Field Immunity	30 A/m, 50 Hz
	EN61000-4-11	Voltage dips, short interruptions	100% interruption for 10 ms

- Safety: EN61010-1:1993 and EN61010-1/A2:1995

### 5. Manufacturer:

NOVUS PRODUTOS ELETRONICOS LTDA  
Rua Alvaro Chaves, 155  
Porto Alegre, RS, BRAZIL 90220-040

Porto Alegre, 20/APR/2006



Miguel Fachin Jr.  
R&D Director