

FieldLogger in the Cloud

Having access to the cloud (Internet), FieldLogger can be read remotely through a server, giving access to its data from anywhere at any time.

From firmware version 1.40 and configuration software version 1.50 on, FieldLogger can be configured to have its data accessed through the cloud (Internet). In order to accomplish that, it needs connection to the Internet, which implies local network access with privileges to access servers located out of the local network.

In order to request the access to NOVUS cloud server, go to <http://www.novusautomation.com/m2m/new> website and fill the requesting form. Pay attention when selecting the application where FieldLogger will work:

- Routing: NOVUS cloud server allows the access of a Modbus master (example: SCADA) to all the equipment of the remote Modbus network through FieldLogger, but it does not store any data and no chart or table with data can be viewed. Only the connection status can be checked.

NOVUS Cloud Server

[Home](#) » [Contact Us](#) » [Novus Cloud Server](#)

NOVUS Remote Server Registration

Company Info

Company name:

Contact person:

Email 1:

Email 2: (optional)

Phone 1:

Phone 2: (optional)

Application Info

Application Type: Routing Cloud Data Storage SMS Temperature Monitor

User:

Password:

Company or application name:

Logo: (optional) [Send File](#)

Equipment Info

Number of devices: ▼

Equipment 1

Serial number:

[Send](#)

FieldLogger in the Cloud

- Cloud storage: NOVUS cloud server is the Modbus master responsible to send commands to the FieldLogger and, in case FieldLogger is configured as a gateway to a RS485/Modbus RTU network, also to the remote network devices through the FieldLogger and stores the read data for viewing by the Internet.

NOVUS Remote Server Registration

Company Info

Company name:

Contact person:

Email 1:

Email 2: (optional)

Phone 1:

Phone 2: (optional)

Application Info

Application Type: Routing Cloud Data Storage SMS Temperature Monitor

User:

Password:

Company or application name:

Logo: (optional) [Send File](#)

Equipment Info

Scan Interval: seconds

Time Out: seconds

Number of devices: ▼

Equipment 1

Serial number: (must be 8 digits)

Tag: (up to 16 characters)

Modbus address: (only numbers between 1 and 255)

Number of registers: ▼

	Register name	Modbus read command	Modbus address
Register 1	<input type="text" value="up to 16 characters"/>	<input type="text" value="only numbers"/>	<input type="text" value="only numbers"/>

Equipment 2

Serial number: (must be 8 digits)

Tag: (up to 16 characters)

Modbus address: (only numbers between 1 and 255)

Number of registers: ▼

	Register name	Modbus read command	Modbus address
Register 1	<input type="text" value="up to 16 characters"/>	<input type="text" value="only numbers"/>	<input type="text" value="only numbers"/>

[Send](#)

FieldLogger in the Cloud

Once the form is submitted, wait for an answer from the e-mail novusm2m@novusautomation.com in up to 48 hours (working days) with all needed information to access the remote network (URL, port, etc.) through the cloud server.

Follow these steps to configure FieldLogger to work with the cloud:

1. Ensure FieldLogger is powered and connected. Start the configuration software tool and open its configuration. On the “Ethernet Interface” screen, click on “TCP/IP” button and enable DNS, setting the best option for your application (manually or getting the configuration from DHCP).
2. Click on the “Cloud” button and check the “Enable” option.

The screenshot shows the 'Ethernet Interface' configuration screen. On the left, under 'Services', there is a 'Disable All' checkbox and buttons for 'TCP/IP', 'FTP', 'SMTP', 'SNMP', 'HTTP', 'Modbus TCP', and 'Cloud'. The 'Cloud' button has a green checkmark. Below these is a note: 'Click on the buttons to set up each service.' On the right, under 'Cloud', there is an 'Enable' checkbox which is checked. Below it is an 'Authentication' section with 'IP Address' set to 'gw.novusautomation.c', 'Authentication' set to 'Open', and an empty 'Port' field. Below that is a 'Protocol' section with 'Time out' set to 2 minutes and 'Address' set to 10. There are two radio buttons: 'Modbus TCP' (unselected) and 'Modbus RTU over TCP' (selected). At the bottom, there are navigation buttons: 'Back', a save icon, a lightning bolt icon, a refresh icon, a red 'X' icon, and 'Next'.

3. Fill the “IP Address” with the “gw.novusautomation.com” URL. Authentication must be “Open”. Select the “Modbus RTU over TCP” protocol.
4. Send configuration to the equipment.